






RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
Kanakapura Sub Division Laboratory, 2nd floor, Mini vidhana Soudha (Taluku Adalitha Soudha)

TEST REPORT					
Address of the sampling location : Saketh Mother Teresa School, Sathanur.				Report date: 08-05-2023	
				Report Number: 19	
				Reference: TRF	
				Sample receipt date: 06-05-2023	
				Sample code: PVT0019	
				Date of Sample collection: 06-05-2023	
				Analysis started date: 06-05-2023	
				Analysis completion date: 08-05-2023	
Sample Particulars: Ro Water				Sample quantity: 1 Ltr	
Sl.No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
Description: Colorless clear liquid					
1	pH Value @25.5°C	6.53	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 1983
2	Specific Conductance, µS/c @24.7°C	31.3	—	—	IS 3025 (Part-14) : 1984
3*	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8):1983
5	Colour, Hazen Units	<1.0	5	15	IS 3025 (Part-4) :2021
6	Turbidity, NTU	<0.5	1	5	IS 3025 (Part-10) : 1984
7	Total Dissolved Solids@ 180°C, mg/l	16	500	2000	IS 3025 (Part-16) : 1984
8	Alkalinity as CaCO ₃ , mg/l	12.1	200	600	IS 3025 (Part-23) : 1986
9	Total Hardness as CaCO ₃ , mg/l	24.2	200	600	IS 3025 (Part-21) : 2009
10	Calcium as Ca, mg/l	8.0	75	200	IS 3025 (Part-40) : 1991
11	Magnesium as Mg, mg/l	0.98	30	100	IS 3025 (Part-46) : 1994
12	Chloride as Cl, mg/l	3.9	250	1000	IS 3025 (Part-32) : 1988
13	Sulphate as SO ₄ , mg/l	16.9	200	400	IS 3025 (Part-24) : 1986
14	Fluoride as F, mg/l	0.52	1	1.5	APHA 23 rd Edition
15	Nitrate as NO ₃ , mg/l	2.0	45	No relaxation	APHA 23 rd Edition
16	Iron as Fe, mg/l	<0.1	1	No relaxation	IS 3025 (Part-53) : 2003
Remarks: The given sample meets the IS10500:2012 requirement for the above tested parameter					
 Analysed By Analyst		RDWSD Water Quality Lab Kanakapura.		 Verified By Assistant Executive Engineer	

Note:

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01.


 Principal
 Saketh Mother Teresa School
 Sathanur, Kanakapura Taluk

SRI TIRUMALA EDUCATION
 AND CHARITABLE TRUST (R)

 MANAGING TRUSTEE

Annexure C

Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 06/2023-24

Dated: 06/11/2023

It is certified that an inspection team headed by Rural Drinking water & Sanitary Dept Kanakapura
(Name of Officers with designation) from Anusha M (Chemist)
(Name of Department/ Office) inspected the Saketh Mother Teresa School, Sathaur
(Name & Address of the school) on 06/11/2023 (date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.
The above is valid for a period of 6 Months.

Signature with Seal: RDWSD
Water Quality Lab
Kanakapura,

Name : Anusha M

Designation : Chemist

Assistant Engineer of
the Govt. Public Health Department (PHED)/
Authorised officer of the Local Body

Name & Address of the Office / Department :

To

Saketh Mother Teresa School
Sathaur.

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

Hanvi B.M
Principal
Saketh Mother Teresa School
Sathaur, Kanakapura Taluk

SRI TIRUMALA EDUCATION
AND CHARITABLE TRUST,
lab
MANAGING TRUSTEE